

COCHRANE



2025 Collection System

CLI ECA 207-W601

Annual Performance Report

This report is prepared to comply with the Environmental Compliance Approval for a Municipal Sewage Collection System ECA Number 207-W601 issued May 21, 2024. This report shall contain:

(a) Summary of all required monitoring data along with an interpretation of the data and any conclusion drawn from the data evaluation about the need for future modifications to the Authorized Systems or system operations;

- *No required monitoring, the pumping stations are not equipped with flow meters to records data.*

(b) Includes a summary of any operating problems encountered and corrective actions taken;

- *In the collection system, when problems are encountered, the lines are flushed to ensure flow.*
- *PS # 2 pump was rebuilt and installed.*
- *PS # 5 pump amperage is monitored to ensure pumps are not blocked. When amperage is high pumps are pulled to unblock.*
- *PS #4 rebuilt and installed second pump*

(c) Include a summary of all calibration, maintenance and repairs carried out on any major structure, equipment, apparatus, mechanism, or thing forming part of the Municipal Sewage Collection System;

Collection System

- *Sanitary sewer flushing was completed 75% of the town by E360*

Pumping Station # 2

- *Annual maintenance on generator*
- *Rebuilt and installed pump*

Pumping Station # 4

- *Rebuilt and installed pump*

Pumping Station # 5

- *Pulled pump numerous time*

(d) Includes a summary of any complaints related to the Sewages Works received during the reporting period and any steps taken to address the complaints;

- *We Received 4 sewage backup complaints this year, all issues with investigated. The sewer mains were flushed in the area, if the issue continued the customer contacted plumber.*

(e) Includes a summary of all alterations to the authorized system within the reporting period that are authorized by this approval including a list of alteration that pose a significant drinking water threat;

- *None*

(f) Includes a summary of all collection system overflow and spills of sewage;

- *None*

(g) Include a summary of efforts made to reduce collection system overflows, spills, STP overflows, and/or STP bypasses;

None

This is the report of the Cochrane Sewage Collection System for the year of 2025. I certify that the information in this document and all the attachments is correct, accurate and complete to the best of my knowledge.

Prepared by,

Melissa Hoogenhoud

Environmental Services and Compliance Supervisor